

IMPIANTO	TIPO DI CAMPIONE	Data prelievo	INGRESSI								Data prelievo	USCITE											
			pH u di pH	COD mg/l O ₂	BOD ₅ mg/l O ₂	Sol.Sosp. tot. 105°C mg/l	NH ₄ mg/l	Azoto totale (N) mg/l	P.Tot. mg/l	Tens. tot. mg/l		cloruri	pH di pH	u	COD mg/l O ₂	BOD ₅ mg/l O ₂	Sol.Sosp. tot. 105°C mg/l	Azoto nitrico(N) mg/l	Azoto nitroso (N) mg/l	NH ₄ mg/l	Azoto totale ** (N) mg/l	P.Tot. mg/l	Tens. tot. mg/l
SALSOMAGGIORE	AUTOCONTROLLO	24/06/2014	7,32	27,3	64	26	30,1	35	4,5		711	25/06/2014	7,47	15	8	6	10,6	0,06	1,3	14,3	0,979		436
	LIMITI	Tab 3 All.5 152/99	5,5-9,5	500	250	200	30		10	10	1200	Tab 1, 3 All.5 152/99	125	25	35	20	0,6	5	15	2	2	1200	

IMPIANTO	TIPO DI CAMPIONE	Data prelievo	INGRESSI								Data prelievo	USCITE											
			pH u di pH	COD mg/l O ₂	BOD ₅ mg/l O ₂	Sol.Sosp. tot. 105°C mg/l	NH ₄ mg/l	Azoto totale (N) mg/l	P.Tot. mg/l	Tens. tot. mg/l		cloruri	pH di pH	u	COD mg/l O ₂	BOD ₅ mg/l O ₂	Sol.Sosp. tot. 105°C mg/l	Azoto nitrico(N) mg/l	Azoto nitroso (N) mg/l	NH ₄ mg/l	Azoto totale ** (N) mg/l	P.Tot. mg/l	Tens. tot. mg/l
FIDENZA	AUTOCONTROLLO	17/06/2014	7,65	37,5	80	102	15,9	23	4,21			18/06/2014	7,80	17,00	1,00	1,00	5,01	0,38	1,30	8,21	0,50		
	LIMITI	Tab 3 All.5 152/99	5,5-9,5	500	250	200	30		10	10	1200	Tab 1, 3 All.5 152/99	125	25	35	20	0,6	15	15	2	2	5000	

IMPIANTO	TIPO DI CAMPIONE	Data prelievo	INGRESSI								Data prelievo	USCITE											
			pH u di pH	COD mg/l O ₂	BOD ₅ mg/l O ₂	Sol.Sosp. tot. 105°C mg/l	NH ₄ mg/l	Azoto totale (N) mg/l	P.Tot. mg/l	Tens. tot. mg/l		cloruri	pH di pH	u	COD mg/l O ₂	BOD ₅ mg/l O ₂	Sol.Sosp. tot. 105°C mg/l	Azoto nitrico(N) mg/l	Azoto nitroso (N) mg/l	NH ₄ mg/l	Azoto totale ** (N) mg/l	P.Tot. mg/l	Tens. tot. mg/l
BUSSETO	AUTOCONTROLLO	24/06/2014	7,62	208,00	15,00	142,00	24,90	28,00	4,91			25/06/2014	7,65	15,00	15,00	8,00	20,00	0,02	1,30	25,40	0,50		
	LIMITI	Tab 3 All.5 152/99	5,5-9,5	500	250	200	30		10	10	1200	Tab 1, 3 All.5 152/99	125	25	35	20	0,6	15	15	2	2		