

IMPIANTO	TIPO DI CAMPIONE	Data prelievo	INGRESSI								Data prelievo	USCITE												
			pH u di pH	COD mg/l O ₂	BOD ₅ mg/l O ₂	Sol.Sosp. tot. 105°C mg/l	NH ₄ mg/l	Azoto totale (N) mg/l	P.Tot. mg/l	Tens. tot. mg/l		cloruri	pH di pH	u	COD mg/l O ₂	BOD ₅ mg/l O ₂	Sol.Sosp. tot. 105°C mg/l	Azoto nitrico(N) mg/l	Azoto nitroso (N) mg/l	NH ₄ mg/l	Azoto totale ** (N) mg/l	P.Tot. mg/l	Tens. tot. mg/l	cloruri
SALSOMAGGIORE		25-ott	7,32	202,00	92,00	110,00	53,30	62,00	3,71		1148,00	26-ott			50,70	9,00	14,00	5,57	0,05	1,30	6,96	0,74		763,00
	LIMITI	Tab 3 All.5 152/99	5,5-9,5	500	250	200	30		10	10	1200	Tab 1, 3 All.5 152/99			125	25	35	20	0,6	5	15	2	2	1200

IMPIANTO	TIPO DI CAMPIONE	Data prelievo	INGRESSI								Data prelievo	USCITE												
			pH u di pH	COD mg/l O ₂	BOD ₅ mg/l O ₂	Sol.Sosp. tot. 105°C mg/l	NH ₄ mg/l	Azoto totale (N) mg/l	P.Tot. mg/l	Tens. tot. mg/l		cloruri	pH di pH	u	COD mg/l O ₂	BOD ₅ mg/l O ₂	Sol.Sosp. tot. 105°C mg/l	Azoto nitrico(N) mg/l	Azoto nitroso (N) mg/l	NH ₄ mg/l	Azoto totale ** (N) mg/l	P.Tot. mg/l	Tens. tot. mg/l	Escheric hia Coli UFC/100 ml
FIDENZA	AUTOCONTROLLO	05-lug	7,41	134,00	65,00	54,00	13,00	19,00	2,06			06-lug			16,60	10,00	5,00	6,91	0,06	1,30	9,58	1,42		
	LIMITI	Tab 3 All.5 152/99	5,5-9,5	500	250	200	30		10	10	1200	Tab 1, 3 All.5 152/99			125	25	35	20	0,6	15	15	2	2	5000

IMPIANTO	TIPO DI CAMPIONE	Data prelievo	INGRESSI								Data prelievo	USCITE												
			pH u di pH	COD mg/l O ₂	BOD ₅ mg/l O ₂	Sol.Sosp. tot. 105°C mg/l	NH ₄ mg/l	Azoto totale (N) mg/l	P.Tot. mg/l	Tens. tot. mg/l		cloruri	pH di pH	u	COD mg/l O ₂	BOD ₅ mg/l O ₂	Sol.Sosp. tot. 105°C mg/l	Azoto nitrico(N) mg/l	Azoto nitroso (N) mg/l	NH ₄ mg/l	Azoto totale ** (N) mg/l	P.Tot. mg/l	Tens. tot. mg/l	
BUSSETO	AUTOCONTROLLO	24-mag	7,54	271,00	130,00	108,00	22,20	28,00	2,70			25-mag			24,10	9,00	5,00	9,11	0,02	1,30	10,90	0,70		
	LIMITI	Tab 3 All.5 152/99	5,5-9,5	500	250	200	30		10	10	1200	Tab 1, 3 All.5 152/99			125	25	35	20	0,6	15	15	2	2	