

IMPIANTO	TIPO DI CAMPIONE	Data prelievo	INGRESSI									Data prelievo	USCITE											
			pH u di pH	COD mg/l O ₂	BOD ₅ mg/l O ₂	Sol.Sosp. tot. 105°C mg/l	NH ₄ mg/l	Azoto totale (N) mg/l	P.Tot. mg/l	Tens. tot. mg/l	cloruri		pH di pH	u	COD mg/l O ₂	BOD ₅ mg/l O ₂	Sol.Sosp. tot. 105°C mg/l	Azoto nitrico(N) mg/l	Azoto nitroso (N) mg/l	NH ₄ mg/l	Azoto totale ** (N) mg/l	P.Tot. mg/l	Tens. tot. mg/l	cloruri
SALSOMAGGIORE		24-gen	7,44	316,00	134,00	140,00	52,20	62,10	5,25		740,00	25-gen			25,70	13,00	10,00	4,80	0,45	2,50	12,00	0,50		650,00
	LIMITI	Tab 3 All.5 152/99	5,5-9,5	500	250	200	30		10	10	1200	Tab 1, 3 All.5 152/99			125	25	35	20	0,6	5	15	2	2	1200

IMPIANTO	TIPO DI CAMPIONE	Data prelievo	INGRESSI									Data prelievo	USCITE											
			pH u di pH	COD mg/l O ₂	BOD ₅ mg/l O ₂	Sol.Sosp. tot. 105°C mg/l	NH ₄ mg/l	Azoto totale (N) mg/l	P.Tot. mg/l	Tens. tot. mg/l	cloruri		pH di pH	u	COD mg/l O ₂	BOD ₅ mg/l O ₂	Sol.Sosp. tot. 105°C mg/l	Azoto nitrico(N) mg/l	Azoto nitroso (N) mg/l	NH ₄ mg/l	Azoto totale ** (N) mg/l	P.Tot. mg/l	Tens. tot. mg/l	Escherichia Coli UFC/100 ml
FIDENZA	AUTOCONTROLLO	05-set	7,14	177,00	58,00	63,00	30,60	35,70	2,64			06-set			21,00	13,00	5,00	6,44	0,02	2,85	7,23	1,04		
	LIMITI	Tab 3 All.5 152/99	5,5-9,5	500	250	200	30		10	10	1200	Tab 1, 3 All.5 152/99			125	25	35	20	0,6	15	15	2	2	5000

IMPIANTO	TIPO DI CAMPIONE	Data prelievo	INGRESSI									Data prelievo	USCITE											
			pH u di pH	COD mg/l O ₂	BOD ₅ mg/l O ₂	Sol.Sosp. tot. 105°C mg/l	NH ₄ mg/l	Azoto totale (N) mg/l	P.Tot. mg/l	Tens. tot. mg/l	cloruri		pH di pH	u	COD mg/l O ₂	BOD ₅ mg/l O ₂	Sol.Sosp. tot. 105°C mg/l	Azoto nitrico(N) mg/l	Azoto nitroso (N) mg/l	NH ₄ mg/l	Azoto totale ** (N) mg/l	P.Tot. mg/l	Tens. tot. mg/l	
BUSSETO	AUTOCONTROLLO	22-ago	7,22	164,00	60,00	100,00	15,90	20,00	4,28			23-ago			15,00	9,00	5,00	4,78	0,04	1,30	5,56	1,70		
	LIMITI	Tab 3 All.5 152/99	5,5-9,5	500	250	200	30		10	10	1200	Tab 1, 3 All.5 152/99			125	25	35	20	0,6	15	15	2	2	