

IMPIANTO	TIPO DI CAMPIONE	Data prelievo	INGRESSI								Data prelievo	USCITE												
			pH u di pH	COD mg/l O <sub>2</sub>	BOD <sub>5</sub> mg/l O <sub>2</sub>	Sol.Sosp. tot. 105°C mg/l	NH <sub>4</sub> mg/l	Azoto totale (N) mg/l	P.Tot. mg/l	Tens. tot. mg/l		cloruri	pH di pH	u	COD mg/l O <sub>2</sub>	BOD <sub>5</sub> mg/l O <sub>2</sub>	Sol.Sosp. tot. 105°C mg/l	Azoto nitrico(N) mg/l	Azoto nitroso (N) mg/l	NH <sub>4</sub> mg/l	Azoto totale ** (N) mg/l	P.Tot. mg/l	Tens. tot. mg/l	cloruri
SALSOMAGGIORE	AUTOCONTROLLO	27-ago	7,4	259	75	53	20,8	25	1,63		448	28-ago	7,55		15	4	11	5,74	0,031	1,3	9,09	0,834	468	
	LIMITI	Tab 3 All.5 152/99	5,5-9,5	500	250	200	30		10	10	1200	Tab 1, 3 All.5 152/99			125	25	35	20	0,6	5	15	2	2	1200

IMPIANTO	TIPO DI CAMPIONE	Data prelievo	INGRESSI								Data prelievo	USCITE												
			pH u di pH	COD mg/l O <sub>2</sub>	BOD <sub>5</sub> mg/l O <sub>2</sub>	Sol.Sosp. tot. 105°C mg/l	NH <sub>4</sub> mg/l	Azoto totale (N) mg/l	P.Tot. mg/l	Tens. tot. mg/l		cloruri	pH di pH	u	COD mg/l O <sub>2</sub>	BOD <sub>5</sub> mg/l O <sub>2</sub>	Sol.Sosp. tot. 105°C mg/l	Azoto nitrico(N) mg/l	Azoto nitroso (N) mg/l	NH <sub>4</sub> mg/l	Azoto totale ** (N) mg/l	P.Tot. mg/l	Tens. tot. mg/l	Escherichia Coli UFC/100 ml
FIDENZA	CAMPIONI CONTROLLO SQUADRA ARPA	26-ago	7,68	73	33	21	17,7	18,6	1,8					18,00	2,00	2,00	5,00		2,00	5,80	0,90		210,00	
	LIMITI	Tab 3 All.5 152/99	5,5-9,5	500	250	200	30		10	10	1200	Tab 1, 3 All.5 152/99			125	25	35	20	0,6	15	15	2	2	5000

IMPIANTO	TIPO DI CAMPIONE	Data prelievo	INGRESSI								Data prelievo	USCITE											
			pH u di pH	COD mg/l O <sub>2</sub>	BOD <sub>5</sub> mg/l O <sub>2</sub>	Sol.Sosp. tot. 105°C mg/l	NH <sub>4</sub> mg/l	Azoto totale (N) mg/l	P.Tot. mg/l	Tens. tot. mg/l		cloruri	pH di pH	u	COD mg/l O <sub>2</sub>	BOD <sub>5</sub> mg/l O <sub>2</sub>	Sol.Sosp. tot. 105°C mg/l	Azoto nitrico(N) mg/l	Azoto nitroso (N) mg/l	NH <sub>4</sub> mg/l	Azoto totale ** (N) mg/l	P.Tot. mg/l	Tens. tot. mg/l
BUSSETO	AUTOCONTROLLO	27-ago	7,45	200,00	5,00	95,00	3,22	15,00	0,73			28-ago	7,37		15,00	5,00	7,00	3,12	0,09	1,30	5,00	0,76	
	LIMITI	Tab 3 All.5 152/99	5,5-9,5	500	250	200	30		10	10	1200	Tab 1, 3 All.5 152/99			125	25	35	20	0,6	15	15	2	2