

IMPIANTO	TIPO DI CAMPIONE	Data prelievo	INGRESSI									Data prelievo	USCITE											
			pH u di pH	COD mg/l O <sub>2</sub>	BOD <sub>5</sub> mg/l O <sub>2</sub>	Sol.Sosp. tot. 105°C mg/l	NH <sub>4</sub> mg/l	Azoto totale (N) mg/l	P.Tot. mg/l	Tens. tot. mg/l	cloruri		pH di pH	u	COD mg/l O <sub>2</sub>	BOD <sub>5</sub> mg/l O <sub>2</sub>	Sol.Sosp. tot. 105°C mg/l	Azoto nitrico(N) mg/l	Azoto nitroso (N) mg/l	NH <sub>4</sub> mg/l	Azoto totale ** (N) mg/l	P.Tot. mg/l	Tens. tot. mg/l	cloruri
SALSOMAGGIORE	AUTOCONTROLLO	21-lug-15	7,36	535	304	233	75,2	75,1	6,25		1656	22-lug-15	7,39		27,9	9	5	4,95	0,335	3,28	10,7	1,44		649
	LIMITI	Tab 3 All.5 152/99	5,5-9,5	500	250	200	30		10	10	1200	Tab 1, 3 All.5 152/99			125	25	35	20	0,6	5	15	2	2	1200

IMPIANTO	TIPO DI CAMPIONE	Data prelievo	INGRESSI									Data prelievo	USCITE											
			pH u di pH	COD mg/l O <sub>2</sub>	BOD <sub>5</sub> mg/l O <sub>2</sub>	Sol.Sosp. tot. 105°C mg/l	NH <sub>4</sub> mg/l	Azoto totale (N) mg/l	P.Tot. mg/l	Tens. tot. mg/l	cloruri		pH di pH	u	COD mg/l O <sub>2</sub>	BOD <sub>5</sub> mg/l O <sub>2</sub>	Sol.Sosp. tot. 105°C mg/l	Azoto nitrico(N) mg/l	Azoto nitroso (N) mg/l	NH <sub>4</sub> mg/l	Azoto totale ** (N) mg/l	P.Tot. mg/l	Tens. tot. mg/l	Escherichia Coli UFC/100ml
FIDENZA	CAMPIONI CONTROLLO SQUADRA ARPA	16-nov-15	7,25	237	100	150	60,1	72	3,51			17-nov-15			50,00	17,00	9,00	12,60		0,50	13,20	1,31		52,00
	LIMITI	Tab 3 All.5 152/99	5,5-9,5	500	250	200	30		10	10	1200	Tab 1, 3 All.5 152/99			125	25	35	20	0,6	15	15	2	2	5000

IMPIANTO	TIPO DI CAMPIONE	Data prelievo	INGRESSI									Data prelievo	USCITE											
			pH u di pH	COD mg/l O <sub>2</sub>	BOD <sub>5</sub> mg/l O <sub>2</sub>	Sol.Sosp. tot. 105°C mg/l	NH <sub>4</sub> mg/l	Azoto totale (N) mg/l	P.Tot. mg/l	Tens. tot. mg/l	cloruri		pH di pH	u	COD mg/l O <sub>2</sub>	BOD <sub>5</sub> mg/l O <sub>2</sub>	Sol.Sosp. tot. 105°C mg/l	Azoto nitrico(N) mg/l	Azoto nitroso (N) mg/l	NH <sub>4</sub> mg/l	Azoto totale ** (N) mg/l	P.Tot. mg/l	Tens. tot. mg/l	
BUSSETO	AUTOCONTROLLO	23-giu-15	7,30	184,00	56,00	102,00	43,00	46,40	3,20			24-giu-15	7,25		15,00	5,00	12,00	5,56	0,05	1,30	8,20	0,50		
	LIMITI	Tab 3 All.5 152/99	5,5-9,5	500	250	200	30		10	10	1200	Tab 1, 3 All.5 152/99			125	25	35	20	0,6	15	15	2	2	