

2019_RIEPILOGO MEDIE ANALITICHE IN-OUT DEPURATORI > 2000 AE

Impianto (AE >2.000)	INGRESSI									USCITE									
	pH u di pH	COD mg/l O ₂	BOD ₅ mg/l O ₂	Sol.Sosp. .tot. 105°C mg/l	NH ₄ mg/l	Azoto totale (N) mg/l	P.Tot. mg/l	Boro mg/l	Cloruri mg/l	COD mg/l O ₂	BOD ₅ mg/l O ₂	Sol.Sosp.tot 105°C mg/l	Azoto nitrico (N) mg/l	Azoto nitroso (N) mg/l	NH ₄ mg/l	Azoto totale (N) mg/l	P.Tot. mg/l	Boro mg/l	Cloruri mg/l
San Polo di Torrile	7,07	552,46	270,50	264,91	28,95	37,22	5,41			24,53	8,00	9,33	4,13	0,02	1,17	6,37	0,83		
Fontanellato Capoluogo	7,57	187,40	95,60	128,00	24,40	25,74	2,65			22,00	7,67	6,83	4,04	0,14	1,10	3,20	1,76		
San Secondo P.se	7,22	780,75	376,25	297,75	52,90	69,90	7,27			23,94	6,67	5,83	4,93	0,17	0,99	5,70	1,16		
Roccabianca	7,49	97,45	36,25	45,50	15,83	15,75	1,92			24,17	8,20	9,60	6,76	0,02	2,46	1,55			
Colorno Nord	7,42	377,67	158,33	122,58	64,83	69,65	5,46			36,19	10,50	9,50	9,80	0,11	0,90	3,57			
Colorno Sud	7,23	432,50	182,50	123,17	69,92	62,03	6,01			28,19	8,00	7,17	8,59	0,02	0,90	3,28			
Busseto	7,38	370,75	199,71	200,50	44,60	49,13	7,33			26,75	7,55	7,07	5,56	0,03	2,59	6,97	0,58		
Sissa	7,39	288,00	141,50	161,50	41,95	55,95	5,36			30,85	9,17	9,00	10,17	0,05	0,98	8,00	3,42		
Ronco CC	7,32	245,50	104,17	79,00	42,25	39,68	3,96			24,50	7,17	7,00	6,29	0,02	1,30	3,87			
Fidenza	7,41	227,33	102,25	108,27	27,87	29,69	3,47			25,29	7,06	7,45	7,04	0,16	0,85	8,16	0,85		
Salsomaggiore Terme	7,62	184,67	82,92	101,50	46,23	45,71	3,43	2,12	809,12	25,40	8,24	7,41	4,40	0,25	2,37	7,26	0,86	1,42	509,23
Tabiano	7,43	159,60	63,20	65,20	25,56	28,16	3,44			23,50	7,50	5,33	5,64	0,95	4,58	11,80	2,54		
media tot.	7,38	325,34	151,10	141,49	40,44	44,05	4,64	2,12	809,12	26,27	7,98	7,63	6,44	0,16	1,68	5,81	1,50	1,42	509,23

Data di pubblicazione: 03.02.2020